

**ANALYTICAL RESULTS: Perfluorinated Chemicals by EPA Method 537.1 Safe Drinking Water Analysis**

**Customer: Oneida County Health Department NLS Project: 347233**

**Project Description: Town of Crescent PFAS Testing**

**Project Title: Template: SCI2537.1 Printed: 07/14/2020 06:25**

Sample: 1195906 Town of Crescent Collected: 06/29/20 Analyzed: 07/08/20 - Analytes: 18

ANALYTE NAME	RESULT	UNITS WWB	DIL	LOD	LOQ	MCL	Note
Perfluorohexanoic acid (PFHxA)	15.9	ng/L	1	0.54	1.8		
Perfluoroheptanoic acid (PFHpA)	3.88	ng/L	1	0.27	0.89		
Perfluorooctanoic acid (PFOA)	6.77	ng/L	1	0.66	2.2		
Perfluorononanoic acid (PFNA)	ND	ng/L	1	0.37	1.2		
Perfluorodecanoic acid (PFDA)	ND	ng/L	1	0.65	2.2		
Perfluoroundecanoic acid (PFUnA)	ND	ng/L	1	0.48	1.6		
Perfluorododecanoic acid (PFDoA)	ND	ng/L	1	0.88	2.9		
Perfluorotridecanoic acid (PFTriA)	ND	ng/L	1	0.69	2.3		
Perfluorotetradecanoic acid (PFTeA)	ND	ng/L	1	0.85	2.8		
Perfluorobutanesulfonic acid (PFBS)	21.4	ng/L	1	0.51	1.7		
Perfluorohexanesulfonic acid (PFHxS)	90.6	ng/L	2	0.56	1.9		
Perfluorooctanesulfonic acid (PFOS)	6.65	ng/L	1	0.26	0.87		
N-Methyl perfluorooctane sulfonamidoacetic acid (NMeFOSAA)	ND	ng/L	1	0.50	1.7		
N-Ethyl perfluorooctane sulfonamidoacetic acid (NEtFOSAA)	ND	ng/L	1	0.76	2.5		
Hexafluoropropylene oxide dimer acid (GenX)	ND	ng/L	1	0.36	1.2		
4,8-Dioxa-3H-perfluorononanoic acid (DONA)	ND	ng/L	1	0.29	0.98		
9-chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	ND	ng/L	1	0.19	0.63		
11-chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	ND	ng/L	1	0.39	1.3		

**NOTES APPLICABLE TO THIS ANALYSIS:**

SR = Surrogate recovery was outside QC limits.  
C13-HFPODA recovered below QC limits.

Sample: 1195907 Town of Crescent Field Blank Collected: 06/29/20 Analyzed: 07/09/20 - Analytes: 18

ANALYTE NAME	RESULT	UNITS WWB	DIL	LOD	LOQ	MCL	Note
Perfluorohexanoic acid (PFHxA)	ND	ng/L	1	0.54	1.8		
Perfluoroheptanoic acid (PFHpA)	ND	ng/L	1	0.27	0.89		
Perfluorooctanoic acid (PFOA)	ND	ng/L	1	0.66	2.2		
Perfluorononanoic acid (PFNA)	ND	ng/L	1	0.37	1.2		
Perfluorodecanoic acid (PFDA)	ND	ng/L	1	0.65	2.2		
Perfluoroundecanoic acid (PFUnA)	ND	ng/L	1	0.48	1.6		
Perfluorododecanoic acid (PFDoA)	ND	ng/L	1	0.88	2.9		
Perfluorotridecanoic acid (PFTriA)	ND	ng/L	1	0.69	2.3		
Perfluorotetradecanoic acid (PFTeA)	ND	ng/L	1	0.85	2.8		
Perfluorobutanesulfonic acid (PFBS)	ND	ng/L	1	0.51	1.7		
Perfluorohexanesulfonic acid (PFHxS)	ND	ng/L	1	0.28	0.93		
Perfluorooctanesulfonic acid (PFOS)	ND	ng/L	1	0.26	0.87		
N-Methyl perfluorooctane sulfonamidoacetic acid (NMeFOSAA)	ND	ng/L	1	0.50	1.7		
N-Ethyl perfluorooctane sulfonamidoacetic acid (NEtFOSAA)	ND	ng/L	1	0.76	2.5		
Hexafluoropropylene oxide dimer acid (GenX)	ND	ng/L	1	0.36	1.2		
4,8-Dioxa-3H-perfluorononanoic acid (DONA)	ND	ng/L	1	0.29	0.98		
9-chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	ND	ng/L	1	0.19	0.63		
11-chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	ND	ng/L	1	0.39	1.3		